

33.79
29CW
981



STATE DOCUMENTS COLLECTION

APR 27 1987

MONTANA STATE LIBRARIES
200 N. LYNCH ST.
HELENA, MONTANA 59601

City of **Whitefish**

PLEASE RETURN

Energy Consumption Profile

Montana State Library

3 0864 1004 5840 8

CITY OF WHITEFISH

ENERGY CONSUMPTION PROFILE

Prepared by
Montana Department of Natural Resources & Conservation
Energy Division
32 S. Ewing, Helena, MT 59620
449-4684

MAY 1981

INTRODUCTION

In cities across the state, energy is fast becoming one of the largest operating costs in municipal budgets. What used to be a minor, even inconsequential expenditure, is now the fastest growing cost; it far exceeds even the rate of inflation. With natural gas, electricity, heating oil and motor fuels taking a bigger bite out of city budgets each year, local officials are being faced with difficult choices: cut city personnel and reduce services, or increase taxes. Sometimes both measures are required just to stay even. There is another option - use traditional fuels more efficiently so that the city can provide the same quality of services to citizens with less fuel and with less disruption to city budgets. In order to do this, however, it is necessary for the city to assess how much energy it is using, and how much it is costing NOW.

WHAT IS AN ENERGY CONSUMPTION PROFILE?

This report is a complete documentation of municipal (city operations) energy consumption over the past three fiscal years. It covers all:

electricity - measured in KWH (kilowatt hours)

natural gas - measured in MCF (thousands of cubic feet)

motor fuels - gasoline and diesel measured in gallons

and it lists electric and natural gas consumption by facility and function. It also contains the cost to the city for FY 77-78, FY 78-79, and FY 79-80 of each of the above three fuels, as well as the city's total energy costs for each year.

In addition, this report contains estimates of energy use and energy costs through FY 84-85, based upon past usage.

It is important to note that an energy consumption profile is very different from a building energy audit. A building energy audit requires a walk-through examination of a structure, with specific attention given to building orientation, amount of floor space, number and square-footage of windows, the particulars of the heating system, number and wattage of light bulbs, etc. An energy consumption profile, on the other hand, requires an examination of past and current utility bills, warrants, and other records of fuel purchases. One is not necessarily better than, or a replacement for, the other. However, when used together, the two provide extremely valuable information on energy usage and costs, and what specifically can be done in a particular building, at what cost, to achieve certain dollar savings.

HOW WAS THIS REPORT COMPILED?

The figures given in this report were taken directly from city records. Natural gas and electricity consumption were recorded from the city's monthly utility bills for each separate account. Motor fuels data was collected from warrants. In some cases, additional city records, and information supplied by city staff, supplemented the data.

The figures are presented for fiscal years rather than calendar years 1) because the report is intended to be a budget planning tool; and 2) to avoid breaking the winter season into two separate years. We have provided estimates for the present year, FY 80-81, because the fiscal year is not over.

The projections for future years' energy use were supplied to the Energy Division by the utility companies, in the case of natural gas and electricity, and the U.S. Department of Energy (DOE) in the case of motor fuels. Although we believe we have gone to the best sources possible for this information, all estimates must be viewed with caution; there are many variable factors which make up utility rates: increases allowed by the Public Service Commission, deregulation, the time at which new generating facilities come on line, and the price of Canadian gas which is pegged to OPEC prices. Motor fuel costs will depend upon the world oil situation, and the rate at which new wells are developed in the U.S. There is no doubt that the cost of all traditional fuels is going up; we have done our best to provide accurate estimates on how much and how fast.

In every case, however, projections were based upon past city energy usage and local weather conditions as measured by the 30-year average of heating degree days.* This information was obtained from the nearest U.S. Department of Commerce weather station.

Because we have had one very cold and one very mild winter over the past three years, the 30-year average was factored in to normalize the consumption figures. In cases where there was neither an upward nor downward trend over three years, the data was averaged, and future use and resulting costs were based upon

* A degree day is a term that is used to describe the relationship of energy consumption to outdoor temperature. A heating degree day represents each degree of outdoor air temperature below 65°F., an assumption being made that when the outdoor temperature falls below 65° the heat must be turned on indoors. For example, when the mean daily temperature is 40°F., the heating degree days would number 25.

this average. In cases where there was an evident trend -- usually upward -- we assumed that consumption would continue to increase and we projected usage figures on that percentage basis. All of the calculations assume no conservation measures will be implemented. All of the future cost projections are based upon 1981 dollars; inflation is not factored in.

HOW IS THIS INFORMATION USEFUL?

The information contained in this report can be used in three important ways:

1. for budget planning purposes;
2. to identify and evaluate conservation options;
3. to detect abnormal or unusual increases or decreases in consumption.

1) When fuels were small constant budget items year after year, it required little thought to figure them into a city's annual budget. Today, however, under-estimating consumption or providing services through a colder or snowier than normal winter can leave cities with a large deficit.

Using the utilities' best estimates and combining these figures with the city's historical use patterns and local weather factors, we have tried to provide dollar figures that cities can use with confidence during the budget planning process in providing for municipal energy costs over the next several years. Although any estimate or projection must be viewed with caution, energy will certainly be one of the largest and most volatile items in municipal budgets. In this decade, it is imperative that mayors and council members have the best possible figures to use when planning for this budget item.

2) The information in this report compares fuel consumption for individual facilities over a period of three years. It is therefore simple to see at a glance exactly where the city is spending its energy dollars and which of those expenditures accrue to the general fund. Obviously the buildings or functions which consume the most energy hold the greatest potential for saving the most dollars. When looking for places to reduce fuel use, it is necessary to examine fully the costs and benefits of each option. The consumption data, however, allows

elected officials to pinpoint those areas which merit closer examination.

In cases where conservation measures are implemented, the before and after consumption data will tell local officials whether or not they are saving money by their energy saving measures.

3) Having detailed use information makes it possible to identify unusual or excessive fuel usage. Only when there is an easily usable record of past consumption would a city staff person or official recognize a significant increase or decrease in a particular building or operation. With an existing record of several years' usage, it is far easier to determine if an unusual usage is caused by weather fluctuations, equipment breakdown, or human error.

CITY OF WHITEFISH, MONTANA
ELECTRIC CONSUMPTION

ACCOUNT	<u>FY 77-78</u>	<u>FY 78-79</u>	<u>FY 79-80</u>
1. Alamar Rd. at Karker Arch	127	131	83
2. Alamar Rd. at Freemans	26	23	48
3. Alamar Rd. Pole at Cab 7	141	35	135
4. 1360 Wisconsin Ave.	4,789	7,667	8,217
5. City Beach Comfort Sta.	340	360	247
6. City Beach Bath House	296	36	42
7. City Beach Int. Sewer	9,842	13,212	10,046
8. City Beach Pump	96,816	87,134	69,431
9. City Beach Lift Pump	7,140	6,968	3,735
10. Lift Sta. Whitefish Ru. Pu. Bt. Hse.	4,606	8,741	3,119
11. Rest Room - 1145 E. 2nd St.	101	845	222
12. Old Dump Site Hwy. 93 S.	2,892	10,912	13,459
13. West Lakeshore Pump	180,800	171,360	-0-
14. Lift Pump New School	3,022	2,399	1,461
15. Lift Pump - 6th & Kalispell	788	783	1,772
16. Next to 1043 Columbia	91,269	100,162	87,535
17. City Yard, S. Somers by R.R.	2,064	2,064	2,064
18. Park/R.R. W.H. Next to Tex. Bulk	19,265	37,011	24,875
19. Lift Station 625 W. 6th St.	47	302	96
20. Lift Station 129 Baker Ave.	23,812	27,997	24,083
21. Lift Station 577 Baker Ave.	4,970	6,183	5,765
22. Lift Station 1320 E. 3rd. St.	1,550	990	960
23. West 2nd Cemetery	57	2	25
24. Lift Pump 225 W. 2nd St.	6,717	6,270	5,765
25. Birch Point Lift Stat. E. at R.R.	1,550	990	960
26. Chlorine Plant	47	2	25
27. Hwy. 93 W. P. RS. by Frenchy H.S.	-0-	17	81
28. Street Lighting	398,657	401,952	406,512
29. City Hall	76,640	74,480	68,400
TOTAL KWH	<u>960,664</u>	<u>1,002,140</u>	<u>1,001,747</u>
UNIT COST	<u>.0304</u>	<u>.0341</u>	<u>.0357</u>
TOTAL COST	<u>\$29,260.87</u>	<u>\$34,188.20</u>	<u>\$35,772.91</u>

CITY OF WHITEFISH, MONTANA
NATURAL GAS CONSUMPTION

ACCOUNT	<u>FY 77-78 MCF</u>	<u>FY 78-79 MCF</u>	<u>FY 79-80 MCF</u>
1. City Hall	2,793	3,471	2,979
2. City Storage	272.2	772.1	384.0
3. City Reservoir	139.7	161.0	130.8
TOTAL MCF	2,828.9	4,401.1	3,493.8
COST PER MCF	2.3540	2.5275	2.8080
TOTAL COST	\$6,660.05	\$11,123.93	\$9,810.87

CITY OF WHITEFISH, MONTANA
MOTOR FUELS CONSUMPTION


	<u>FY 77-78</u> <u>GALLONS</u>	<u>FY 78-79</u> <u>GALLONS</u>	<u>FY 79-80</u> <u>GALLONS</u>
GASOLINE	22,790	28,717	24,292
Cost Per Gallon	.605	.644	1.055
Total Cost	\$13,788.42	\$18,493.74	\$25,628.06
DIESEL FUEL	9,800	9,800	9,800
Cost Per Gallon	.605	.644	1.055
Total Cost	\$ 5,929.00	\$ 6,311.20	\$10,399.00
GRAND TOTAL GALLONS	32,590	38,517	34,092
GRAND TOTAL COST	\$19,717.42	\$25,804.94	\$35,967.06

CITY OF WHITEFISH, MONTANA
ENERGY COSTS AND PROJECTIONS

FISCAL YEAR	ELECTRICITY	NATURAL GAS	MOTOR FUELS	TOTAL ENERGY COSTS IN DOLLARS
77-78	960.664	2,828.9	22,790	
78-79	1,002.140	4,401.1	28,717	
79-80	1,001.747	3,493.8	24,292	
80-81	1,029.267	3,700.0	26,768	
81-82	1,049.808	3,700.0	27,519	
82-83	1,070.350	3,700.0	28,270	
83-84	1,090.891	3,700.0	29,021	
84-85	1,111.433	3,700.0	29,772	
	<u>AVERAGE COST PER KWH</u>	<u>AVERAGE COST PER MCF</u>	<u>AVERAGE COST PER GALLON</u>	
77-78	.0304	2.3540	.605	
78-79	.0341	2.5275	.644	
79-80	.0357	2.8080	1.055	
80-81	.0388	3.4480	1.345	
81-82	.0419	3.7926	1.890	
82-83	.0452	4.1719	2.250	
83-83	.0488	4.5891	2.665	
84-85	.0527	5.0067	3.019	
	<u>TOTAL COST IN DOLLARS</u>	<u>TOTAL COST IN DOLLARS</u>	<u>TOTAL COST IN DOLLARS</u>	
77-78	\$29,260.87	\$ 6,660.05	\$13,788.42	\$ 49,709.34
78-89	34,188.20	11,123.93	18,493.74	63,805.87
79-80	35,772.91	9,810.87	25,628.06	71,211.84
80-81	39,935.55	12,757.60	38,813.60	91,506.75
81-82	43,986.95	14,032.62	52,010.91	110,030.48
82-83	48,379.82	15,436.03	63,607.50	127,423.35
83-84	53,235.48	16,979.67	77,340.96	147,556.11
84-85	58,572.51	18,524.79	92,025.25	169,122.55

Electrical Consumption Kilowatt Hours & Dollars


WHITEFISH



GRAPH B


Natural Gas Consumption MCFs/Dollars

WHITEFISH



GRAPH C
Gasoline and Diesel Fuels
in Gallons and Dollars

WHITEFISH



RECOMMENDATIONS

- Lower thermostats to 65-68° in winter; raise to 78° in summer during working hours. Turn air conditioning or ventilation off after hours and on weekends (summer) and turn thermostats down to 60° after hours and on weekends during winter.
- Close off infrequently-used rooms and turn the heat down to 50-55° when not in use.
- Close all drapes, blinds, or shades overnight during winter.
- Turn off the heat one-half hour to one hour before the end of the working day. Almost all buildings can "coast" for at least one-half hour with the boiler off.
- Turn off any and all lights when not in use. At today's electricity rates, it is cheaper to turn a light off, even when a room is left unoccupied for only five minutes.
- Use natural light whenever possible and turn off ceiling fixtures.
- Replace incandescent with florescent or other energy-efficient fixtures wherever possible.
- Use task lighting whenever possible -- disconnect every other overhead fixture and place individual lamps on each desk.
- Turn off typewriters and other office equipment and machinery when not in use.
- Reduce lighting levels in hallways and staircases to minimum safe level.
- Turn down restroom water heaters to 105° in winter, and turn them completely off in summer.
- Open shades, blinds, or drapes on south-facing windows on sunny winter days. Close them on hot summer days.
- Reduce heating in fire engine rooms to lowest minimum level that will allow firefighters to perform routine maintenance on fire trucks.
- Park police patrol cars with engines off for at least half of every patrol

hour. (The Bozeman Police Department has been using this system and has found that it not only saves energy but increases the ticketing of violators.)

- Purchase more fuel-efficient police vehicles as older cars wear out.

- Buy, or lease, motorcycles for use by patrolmen during the summer.

- Turn off the motor in any city automobile which stands still for more than 30 seconds.

- Install heavy duty batteries and generators in street equipment so that accessories - flashing lights, etc. - can operate with the engine off.

- Switch traffic signals to red or yellow blinking lights at night and, where safe, on Sundays.

- Purchase and install pool covers on all outdoor swimming pools. This is one of the most effective money savers for any city. The pool should be covered every night. In cases where the pool is not in use through the day, it should be covered with a thermal cover which actually absorbs the sun's warmth and heats the water.

- Install one-hour timers on tennis court floodlights, so that lights are in use only when courts are in use.

Most of the above options can be undertaken at little or no cost and will result in immediate savings. It is a generally accepted conclusion that energy use in most buildings can be cut by at least 25% merely by conscientious attention to turning out lights, keeping thermostats down, closing off unused rooms, and similar simple measures. The next 25% saving usually requires some thought and monetary investment. However, there are many options that will save enough energy dollars to pay for themselves in a year or less. The advantage of these, of course, is that the city need not budget extra dollars. Instead of paying for fuel, the city instead spends the dollars allocated to energy bills on fuel saving installations.

It is important, therefore, before investing in energy saving devices or installations, that local officials investigate the cost and payback period (time

it takes for a device to save enough energy to pay for itself) before deciding which ones will best meet the city's needs.

After this decision has been made, it is equally important that energy consumption (not dollars, because they are going up regardless) be compared before and after the change. Only by making this comparison will the city know if it is saving energy, and if it is saving enough to warrant using similar measures in other structures.

Finally, when a city does save, through conservation, dollars that would otherwise have been spent on fuels, then it only makes sense to take those dollars budgeted, but not spent, for fuels, and invest them in conservation equipment or retrofits. A mild winter like the one just past will probably leave most cities with extra dollars which could be spent to insure savings on next year's energy costs. Anticipating energy prices for this decade, there is probably no better investment of dollars for any city. In most cases, investing in reducing next year's energy bills will probably save more money than a bank account or traditional investment will return. Of course, each year, as energy costs get higher and higher, conservation investments made today, yield a higher and higher return.

100 copies of this public document were published at an estimated cost of \$1.20 per copy, for a total cost of \$120.66, which includes \$107.46 for printing and \$13.20 for distribution.